



**SECTION A-A**

**NOTES**

1. Kerb ramps to be constructed of the same material that is used in the area or as directed by the supervising engineer.
2. Asphalt ramp to be 30mm compacted depth of 7mm nom. asphalt on 75mm compacted depth of 20mm class 2 fine crushed rock.
3. Concrete ramp to be 125mm depth of 25Mpa concrete on 75mm compacted fine crushed rock or recycled crushed concrete.
4. Minimum height of kerb ramp to be to the top of kerb.
5. All footpaths to grade from building line as shown and grade towards a grated pit in either or both of the positions as shown.

 <p><b>Bayside</b> CITY COUNCIL</p>	Drawing Title <h2 style="margin: 0;">KERB RAMP WITH REVERSE CROSS FALLS</h2>		Drawing No. <h2 style="margin: 0;">BCC406</h2> Page 1 of 1	Rev: <h2 style="margin: 0;">A</h2>
	Scale <h3 style="margin: 0;">1:20, 1:100</h3>		Approved Manager Engineering Services 	
	References to: BCC201, BCC202		Date: 18-Dec-08	